INSPECTION REPORT

PERMIT NUMBER:	BP-14-00815	OWNER'S NAME:	JILL BROWN LIVING TRUST
DATE:	3/13/2015	TYPE:	Framing
TIME STARTED:	2:50 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	19-16-06020-0018		
1. Truss	Bracing Not Complete Pe	er Truss Sheet	s. Truss ID: T01
2. Provide Engineers Approval for Outlooker.			
3. H1s or Equivalent Not Installed on Every Truss per Detail 1/S3.			
4. Provide Engineers Approval for 6x6 Corner Post to GluLam Connection.			
5. Provide Engineers Approval for 2x10 Parralam Header Substitution.			
INSTRUCTIONS: Make Corrections Above.			
NEXT INSPECTION: Call for Reinspection.			
RE-INSPECTION FEE I	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jeremy.haberman @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •			