



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00818

OWNER'S NAME: CAHILL

DATE: 6/19/2015

TYPE: Framing

TIME STARTED: 11:15 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-20058-0094

	1. Trusses OK.
	2. Bonus Room Windows Not Egress. See Plan Review Note in Red on A6.
	3. Truss Clips Required at Truss Tails of B01, C01, C02
	4. Handrail will be required at Garage Stairs at Final.

INSTRUCTIONS: OK to Insulate.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?

☒ NO

☐ YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506