



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00818 OWNER'S NAME: CAHILL
DATE: 6/29/2015 TYPE: Re-inspection
TIME STARTED: 11:29 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-15-20058-0094

	1. Insulation Corrections OK.
	2. Framing Corrections OK.
	3. Bonus Room Window Not Egress. See Plan Review Note on A6.
	4. Interior Shearwall Inspection Not Complete. P2 Shearwalls Not Complete.

INSTRUCTIONS: COMPLETE INTERIOR P2 SHEARWALLS. CALL FOR INSPECTION. DO NOT COVER P2 WALLS PRIOR TO INTERIOR SHEARWALL INSPECTION.

NEXT INSPECTION: Interior Shearwalls.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506