INSPECTION REPORT

OWNER'S NAME: GRADY

TYPE:

Final

PERMIT NUMBER: BP-14-00840

DATE:

6/29/2015

TIME STARTED:		11:04 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:		18-20-32053-0001		
	1. Not ready for final			
	2. cable bracing not per plan. 3/8" and 1/2" switched installation in roof and endwalls			
	3. bolting ok			
INSTRUCTIONS: call for framing when lean to addition is framed up				
NEXT INSPECTION: framing				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
iessica_contratto @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506				
, , , , , , , , , , , , , , , , , , , ,				