INSPECTION REPORT

PERMI	T NUMBER:	BP-14-00840	OWNER'S NAME:	GRADY	
DATE:		10/2/2015	TYPE:	Framing and plumbing	
TIME STARTED:		2:57 PM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:		18-20-32053-0001			
	1. Steel Stru	ructure OK. Per JC 6/9/15.			
	2. Plumbing Rough In OK.				
	3. Supply @ 50#/15min. DWV on Stack Test.				
	4. Mechanical Exhaust Not Complete Will See at Insulation.				
	5. Framing OK per Engineer.				
	6. Revised Floor Plan OK.				
INSTRUCTIONS: OK to Insulate					
NEXT INSPECTION: Insulation.					
RE-INSPECTION FEE DUE? V NO YES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	ieremv.haberman @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 					