



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00017

OWNER'S NAME: DONOVAN

DATE: 1/21/2015

TYPE: Stove or fireplace

TIME STARTED: 10:45 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-32051-0004

	1. Clearances do not meet minimums outlined in installation manual.

INSTRUCTIONS: Will verify with manufacturer for reduces allowable clearances.

NEXT INSPECTION: Final.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506