



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00094

OWNER'S NAME: EATON

DATE: 9/29/2015

TYPE: Re-inspection

TIME STARTED: 12:31 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-13050-0014

	1. Prior Corrections Outstanding
	2. Garage Plumbing OK. DWV on Stack Test. OK. Supply @ 60#/15min. OK

INSTRUCTIONS: Continue for Framing Inspection.

NEXT INSPECTION: House Plumb/Mech?? Framing??

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506