INSPECTION REPORT

PERMIT NUMBER:		BP-15-00112	OWNER'S NAME:	CASCADE VIEW INC	
DATE:		5/13/2015	TYPE:	Frame-Plumb-Mech	
TIME STARTED:		9:17 AM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:		18-18-27071-0147			
	1. Mechar	. Mechanical Not Complete. Exhaust Fan In Kitchen Not Connected to Duct.			
	2. Vented Windows will be Required Downstairs for Final.				
	3. Supply OK. 70#/15min.				
	4. DWV OK. Stack Test.				
	5. Trusses OK.				
	6. Upper and Lower Stair Jack Attachment to Parralam Not Acceptable. Stair Jack Must Fully				
	Bear.				
INSTRUCTIONS: Make Coorrections Above. OK to Insulate.					
NEXT INSPECTION: Insulation/Re Inspect.					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	jeremy.haberman @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 					