



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00120

OWNER'S NAME: KITTITAS COUNTY HA

DATE: 4/27/2016

TYPE: Floor framing

TIME STARTED: 9:45 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-16-24051-0914

1. STD14RJ's do not work as installed - Provide engineer fix
2. Do not cover the east side of the floor in the area with corrections

INSTRUCTIONS: Do not cover area with corrections/Provide engineer fix for STD14RJ's/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506