



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00124

OWNER'S NAME: TYLER

DATE: 12/15/2015

TYPE: Gas piping

TIME STARTED: 3:07 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29050-0029

	1. Radon Piping OK.
	2. Barrier to Be Seen at Floor Framing

INSTRUCTIONS:

NEXT INSPECTION: Floor Framing.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506