



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00134

OWNER'S NAME: TUMBLE CREEK GOLF

DATE: 7/24/2015

TYPE: Slab plumbing

TIME STARTED: 1:44 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-24050-0003

| | |
|--|---|
| | 1. Slab insulation ok |
| | 2. slab plumbing ok-stack |
| | 3. obtain engineer letter for mesh in slab and reduced slab thickness |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: ok to cover

NEXT INSPECTION: slab reinforcement/thickened footings

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506