



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00134

OWNER'S NAME: TUMBLE CREEK GOLF

DATE: 10/9/2015

TYPE: Rough-in plumbing

TIME STARTED: 2:53 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-24050-0003

| | |
|--|---------------------------------|
| | 1. OK DWV STACK TEST 20 MINUTES |
| | 2. OK H2O @ 60#'S 20 MINUTES |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS:

NEXT INSPECTION: ROUGH-IN MECHANICAL

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506