



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00134 OWNER'S NAME: TUMBLE CREEK GOLF  
DATE: 12/31/2015 TYPE: Final  
TIME STARTED: 10:56 AM INSPECTOR: Jeremy Haberman  
MAP NUMBER: 20-14-24050-0003

	1. Mens and Womens Restroom Must Be Labeled per IBC.
	2. ADA Parking Stall Must be Painted and Signage Installed per ANSI. See Detail 1 on C3.
	3. Exposed Insulation Must be Removed or Covered with Approved MAterial.
	4. FIRE MARSHAL FINAL NOT COMPLETE.
	5. Electrical Final OK.
	6. Plumbing Final OK.
	7. Mechanical Fianl OK.
	8. Sewer Connection Verification Letter Required from Utility.
	9. Access OK.
	10. BUILDING AND FIRE REQUIRE CHEMICAL AND FERTILIZER ROOMS BE LABELED PE

INSTRUCTIONS: MAke Corrections Above.

NEXT INSPECTION: Re Inspect Final

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremv.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506