



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00143

OWNER'S NAME: BV RESORT HOMES

DATE: 5/31/2016

TYPE: Framing

TIME STARTED: 12:12 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19051-0038

1. Drawings/Truss Sheets not on site - Corrections cannot be confirmed
2. Install vapor barrier @ Shower (Master?) on exterior wall
3. DO NOT COVER

**INSTRUCTIONS:** Do Not Cover/Install Vapor Barrier/Provide drawings and truss sheets/Re-Inspection

**NEXT INSPECTION:** Re-Inspection

**RE-INSPECTION FEE DUE?**



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL

ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506