



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00171

OWNER'S NAME: HABERMAN

DATE: 5/29/2015

TYPE: Exterior shear

TIME STARTED: 9:18 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-31070-0004

	1. Complete nailing at header on garage per 24" PFH detail
	2. Provide panel edge blocking below windows in Living Room
	3. ABW corrections Ok
	4. Exterior shear nailing on living room PFH Ok
	5. Tighten up nailing at panel edges @ garage above center partition

INSTRUCTIONS: Complete items above/Ok to cover

NEXT INSPECTION: Mechanical/Plumbing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506