INSPECTION REPORT

PERMIT NUMBER: BP-15-00171 OWNER'S NAME: HABERMAN

DATE:		7/29/2015	TYPE:	Multiple (see notes)
TIME STARTED:		12:46 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:		18-19-31020-0023		
	Panel quantity does not match engineering			
	2. Racking design does not match engineering			
	3. Provide accurate design for solar installation			
INSTRUCTIONS: Provide accurate solar design for installation/Re Fee/Re-inspection				
NEXT INSPECTION: Re-inspection				
Re-inspection				
RE-INSPECTION FEE DUE? YES \$ 65.00				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
	iustin.bennett @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 ◆ 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506 				
TIT IV. NUDY Street, Suite 2, Literisburg, WA 30320 VIVIAIII Office Litte. 303-302-7300				