



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00187

OWNER'S NAME: ROWLEY

DATE: 7/16/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 10:40 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-17-13020-0006

	1. Provide truss bracing on D5
	2. Mechanical Ok
	3. Waste @ 5#/15 mins - Ok
	4. Supply @ 60#/15 mins - Ok
	5. Framing Ok
	6. Plumbing rough in Ok
	7. Ok to insulate

INSTRUCTIONS: Verify truss bracing @ insulation/Ok to insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506