



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00203 OWNER'S NAME: STRINGFELLOW
DATE: 6/1/2015 TYPE: Mono pour
TIME STARTED: 1:04 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-17-32057-0002

	1. Mono Form OK.
	2. Rebar Verticals Not Per Drawing. Engineer Approval for Verts. on 36" O.C. Pending
	3. Porch Piers Not Excavated or Formed at this time. Possible Revision Pending for Thicken
	ed Porch Slab Alternate.

INSTRUCTIONS: Pour at Own Risk

NEXT INSPECTION: Floor Framing.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506