



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00203

OWNER'S NAME: STRINGFELLOW

DATE: 8/11/2015

TYPE: Rough-in plumbing

TIME STARTED: 12:14 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-17-32057-0002

	1. plans not on site
	2. DWV on stack-ok
	3. H2O is live-ok

INSTRUCTIONS: have plans on site, call for shear inspection before covering

NEXT INSPECTION: shearwalls

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506