

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00208	OWNER'S NAME:	FEASTER
DATE:	11/17/2015	TYPE:	Rough-in mechanical
TIME STARTED:	9:57 AM	INSPECTOR:	Jessica Contratto
	20-14-24050-0112		

1. gas at 17#-ok		
2. Corrections completed		
3. fireplace is gas.		
<b>INSTRUCTIONS:</b> ok to insulate. Complete fire marshal sprinkler inspections		

NEXT INSPECTION: insulate

RE-INSPECTION FEE DUE?

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

iessica.contratto @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506