

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00209	OWNER'S NAME:	FEASTER
DATE:	9/30/2015	TYPE:	Exterior shear
TIME STARTED:	11:18 AM	INSPECTOR:	Jessica Contratto
MAD NIIMBER:	20-14-24050-0112		

1. revisions in review for added bathroom	
2. need to verify slab insulation. Drill hole	
3. engineer approval of panel box in shearwall 1	

INSTRUCTIONS: complete above, ok to cover exterior

NEXT INSPECTION: mechanical

RE-INSPECTION FEE DUE?

V NO

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

iessica.contratto @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506