## **INSPECTION REPORT**

PERMIT NUMBER: BP-15-00209 OWNER'S NAME: FEASTER

DATE:		11/13/2015	TYPE:	Framing	
TIME STARTED:		11:48 AM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:		20-14-24050-0112			
	1. All Truss Bracing Missing on A1 Truss. See Truss Sheet A1.				
	2. Attic Access Opening Framing Not Complete.				
	3. NOTE: MECHANICAL INSPECTION NOT REQUESTED. EXHAUST OK. MINI SPLIT OK.				
INSTRUCTIONS: Make Corrections Above. OK to Insulate. Will See Corrections at Insulation Inspection.					
NEXT INSPECTION: Insulation					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	ieremv.haberman @co.kittitas.wa.us				
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>					