



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00220

OWNER'S NAME: MCCONNELL

DATE: 2/24/2017

TYPE: Insulation

TIME STARTED: 10:01 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-19-33030-0013

1. Window at master tub not tempered
2. Trusses ok
3. Framing corrections ok
4. Current framed exterior crawl access will be deleted. Interior access in closet will replace. This will remove intent of using crawl for storage purposes
. Use of crawlspace for storage will trigger requirement of fire protection of floor membrane. Owner will not use crawl for storage purposes
5. Wall, floor and duct insulation ok
6. Fireplace draftstop ok

INSTRUCTIONS: Ok to cover

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506