INSPECTION REPORT

TYPE:

OWNER'S NAME: CASCADE VIEW INC

Exterior shear

BP-15-00229

5/22/2015

PERMIT NUMBER:

DATE:

| TIME STARTED: MAP NUMBER: | | 1:07 PM | INSPECTOR: | Amber Green |
|---------------------------|---|--|---------------------|---------------------------------|
| | | 18-18-27071-0149 | | |
| | 1. Interior | shearwall P-4 needs to be ful | I width of garage | e wall. Add studs on north end. |
| | 2. Re-check panel edge nailing at interior shearwall P-4. | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| INSTR | RUCTIONS: (| Ok to Cover Exterior. Will see ab | ove at framing ins | spection. |
| | | | | |
| NEXT | INSPECTION: | Frame/Plumb/Mech | | |
| RE-IN | SPECTION FEI | E DUE? NO YE | S | \$ |
| | IF RE | QUIRED, RE-INSPECTION FEES MUST B | E PAID PRIOR TO SCH | HEDULING A RE-INSPECTION |
| | Q | UESTIONS? PLEASE CONTACT THE INSP | PECTOR AT THE FOLLO | DWING E-MAIL ADDRESS: |
| | | | @со | .kittitas.wa.us |
| | | CTION REQUEST LINE: www.co.kits 11 N. Ruby Street, Suite 2, Ellensburg, | | |
| | | - | | |