



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00229

OWNER'S NAME: CASCADE VIEW

DATE: 6/16/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 8:53 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-27071-0149

	1. DWV OK. Stack Test
	2. Supply OK. 50#/15min.
	3. Mechanical OK.
	4. Fresh Air Intake to Air Handler Verified.
	5. Kitchen Range Vent Not Installed. Verify at Final.
	6. Trusses OK.
	7. Framing OK.
	8. Corrections OK.
	9. Interior Shear OK.

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506