## **INSPECTION REPORT**

PERMIT NUMBER: BP-15-00236 OWNER'S NAME: NEW SUNCADIA LLC

DATE:		12/8/2015	TYPE:	Framing	
TIME STARTED:		12:49 PM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:		20-15-20058-0166			
	Foundation Insulation Verified.				
	2. Framing	2. Framing OK.			
	3. Trusses Require Brace of Web on Single Ply Girder.				
	4. LVL Girder Install to be Verified at Insulation.				
INSTRUCTIONS: OK to Insulate Structure.					
NEXT INSPECTION: Insulation.					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
ieremv.haberman @co.kittitas.wa.us					
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>					