

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

| PERMIT NUMBER: | BP-15-00238 | OWNER'S NAME: | EVERGREEN VALLEY |
|----------------|------------------|---------------|------------------------|
| DATE: | 7/28/2015 | TYPE: | Mechanical and plumbir |
| TIME STARTED: | 12:09 PM | INSPECTOR: | Jessica Contratto |
| MAP NUMBER: | 20-14-12053-0012 | | |

| 1. Incorrect plans on site | | |
|---|--|--|
| 2. DWV at 6#-ok | | |
| 3. H2O at 60#-ok | | |
| 4. permit card not on site | | |
| 5. heating duct ok | | |
| 6. bath fans not installed yet, see by insulation | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| INSTRUCTIONS: call for framing after electrical is installed. Have correct plans on site | | |
| | | |

NEXT INSPECTION: framing

RE-INSPECTION FEE DUE?

יח

V NO

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

iessica.contratto @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506