KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00275	**OWNER'S NAME:**	CENTRAL WASHINGT(
DATE:	10/13/2015	**TYPE:**	Footings
TIME STARTED:	3:37 PM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	18-18-25030-0008		

	1. East and West Grade Beams ReBar Reguires 3" Seperation from Native Material. Install Do
	bies or Tie Then OK.
	2. South Post Footings Install Lateral #4 Bar for Grade Beam Tie Ins Then OK.
	3. Upon Commencement of Welding at Post Facade Installation Welders Certification is Requi
	red to be provided to Inspector.

INSTRUCTIONS: OK to Pour South Footings and East and West Grade Beams.

NEXT INSPECTION: South Grade Beams and Welding Certifications.

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____jeremy.haberman **@co.kittitas.wa.us**

• **INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694** •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506