## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00281	OWNER'S NAME:	MCDANIEL
DATE:	8/17/2016	TYPE:	Insulation
TIME STARTED:	11:33 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-14-12051-0506		
<ol> <li>Trimmer correction Ok</li> <li>Strap correction @ entry Ok</li> <li>SDS correction @ deck ledger not complete</li> <li>Insulation Ok</li> <li>Ok to cover</li> <li>NOTE: Decks not complete (Verify @ Final)</li> </ol>			
INSTRUCTIONS: Ok to cover/Verify deck framing @ Final			
NEXT INSPECTION: Final			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  ADDRESS: <u>iustin.bennett</u> @co.kittitas.wa.us			

**INSPECTION REQUEST LINE: 509-962-7694** 

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506