



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00292 **OWNER'S NAME:** STRADER
DATE: 11/24/2015 **TYPE:** Framing
TIME STARTED: 12:51 PM **INSPECTOR:** Jeremy Haberman
MAP NUMBER: 20-15-19050-0145

	1. Fireplace Corrections OK.
	2. NOTE: ELECTRICAL INSPECTION NOT COMPLETED. REQUIRED FOR FRAMING INSP
	3. SHEAR HOLDDOWNS AT P1-3 Shear walls at Garage Door Do Not Appear to be Per Plan.
	4. Interior Shear OK.
	5. Trusses OK
	6. Framing OK.

INSTRUCTIONS: Make Corrections Above. OK to Insulate.

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506