



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00299

OWNER'S NAME: PERAVOZ

DATE: 4/12/2016

TYPE: Mechanical

TIME STARTED: 1:37 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-14-34060-0003

1. Hydronic Tubing on Test. (3) Manifolds All at 100#/15min.
2. Solid Fuel Burning Fireplace Rough In OK.

INSTRUCTIONS: OK to Cover Floors and Fireplace Surround.

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506