



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00299

OWNER'S NAME: PERAVOZ

DATE: 6/14/2016

TYPE: Mechanical

TIME STARTED: 1:05 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 21-14-34060-0003

1. Corrections received for prior.
2. Truss bracing on 26,27,28,
3. H1 to outlooker over gable truss, typical throughout
4. Complete blocking along stairs in walls, typical
5. Blocking per 3/S4.1 page A12
6. Note that high density or spray foam must be used in vault top chord over garage, or furr down for R-38

INSTRUCTIONS: Complete above, see at insulation. Ok to insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506