



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00299

OWNER'S NAME: PERAVOZ

DATE: 6/21/2016

TYPE: Insulation

TIME STARTED: 11:58 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-14-34060-0003

1. CORRECTIONS NOT COMPLETE.
2. INSULATION NOT COMPLETE.
3. Truss Sheets Not Onsite for Truss Bracing Verification of Truss 26,27,28.
4. Fire Blocking at Stairs Not Complete.
5. Rafter Bays in Bonus Room Over Garage Not Vented. Blocked By Outlookers. Spray Foam Required.

INSTRUCTIONS: Make Corrections Above.

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?

NO

YES

\$ 86.00

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506