



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00329

OWNER'S NAME: LYNCH

DATE: 7/17/2015

TYPE: Footings

TIME STARTED: 12:19 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-17-15040-0002

	1. CMU epoxy reinforcement Ok
	2. Set second course, grout cells and install anchor bolts per plans

INSTRUCTIONS: Once second course is installed ok to grout

NEXT INSPECTION: Exterior shear

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506