



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00335

OWNER'S NAME: BELSAAS

DATE: 7/27/2015

TYPE: Re-inspection

TIME STARTED: 8:52 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-04010-0007

	1. Setbacks OK.
	2. F1 Footings Not Per Plan. Engineers Letter will OK Wider Shallower Footing. 2 Wide and
	3. Deep Permitted. 3 Wide and 2 Deep Observed.
	3. (4) Additional Post Holes Dug 3 Wide and 2 Deep Along Existing Pole Structure to Supo
	rt Ledger Not Per Plan. Revision Required.
	4. Email Photos of Rebar Thru Post Required Prior to Pour.

INSTRUCTIONS: OK to Pour at Owners Risk.

NEXT INSPECTION: ReInspect?/Final

RE-INSPECTION FEE DUE?

☒ NO

☐ YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506