



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00351

OWNER'S NAME: VAUGHN

DATE: 9/8/2015

TYPE: Mono pour

TIME STARTED: 10:58 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-12052-0003

	1. Setbacks OK.
	2. Mono Pour OK.
	3. Tall Retaining Wall OK per Owner Provided Engineering.
	4. NOTE: Slab Pour Required Prior to Backfill.
	5. Garage House Orientation Not Per Submitted Site Plan.
	6. Garage Not Per Plan. Garage is approx. 1/2 width of Submitted Plan.

INSTRUCTIONS: Revised Site Plan Required. Revision Required for Garage Dimension Changes. OK to Pour at Owners Risk.

NEXT INSPECTION: Framing.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506