## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00365	OWNER'S NAME:	FORTUNE CREEK LLC
DATE:	1/20/2016	TYPE:	Framing
TIME STARTED:	11:01 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	19-15-07061-0028		
1. Corrections not complete			
2. Verify A35's per 3/S2.2			
3. CS strapping not installed per plan			
4. Strapping not installed @1st Flr beam per 8/S3.2			
5. Window 4x6 does not connect to header in multiple locations			
6. 4x4 post in SW1 in Master resting on 2x4's @ Floor			
INSTRUCTIONS: Per 1/11/16 inspection report - Provide As-Built Approval from engineer for framing			
corrections.			
NEVT INSDECTION:			
NEXT INSPECTION: Re-Inspection			
RE-INSPECTION FEE DUE? YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
<u>iustin.bennett</u> @co.kittitas.wa.us			
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>			