



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00365

OWNER'S NAME: FORTUNE CREEK

DATE: 6/24/2016

TYPE: Final

TIME STARTED: 11:40 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-15-07061-0028

1. Smoke/CO needed outside of bedrooms in basement
2. Smoke detector needed in rec room per plan
3. Septic/access approval not verified
4. Final not called in for garage but a landing must be provided at the man door for final
5. All other conditions passing

INSTRUCTIONS: Complete above, call both permits for inspection

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506