INSPECTION REPORT

TYPE:

PERMIT NUMBER:

DATE:

BP-15-00366

7/13/2015

OWNER'S NAME: CASCADE VIEW INC

Shearwalls

TIME STARTED:	9:09 AM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	18-17-36057-0004		
1. All Nailing OK.			
2. Straps or HDUs Missing at Middle Garage Wall.			
3. (7/20/2015: Verify Shear Corrections at Framing Inspection.)			
INSTRUCTIONS: Make Correcttions Above. OK to Cover Exterior			
NEXT INSPECTION: Plumb/Mech			
RE-INSPECTION I	FEE DUE? NO '	YES	\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jeremy.haberman @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 			