



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-15-00366

OWNER'S NAME: D & H RANCH

DATE: 7/17/2015

TYPE: Multiple (see notes)

TIME STARTED: 12:56 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-17-36057-0004

	1. DWV OK. 5#/15miin.
	2. Supply OK. 60#/15min.
	3. Exhaust Fans Not Installed. Ducts Not Connected.
	4. Supply Heating Flex Duct Kinked Over Main Living Space.
	5. (7/20/2015: Verify Shear Corrections at Framing Inspection)

**INSTRUCTIONS:** Make Corections Above then OK to Schedule Framing Inspection.

**NEXT INSPECTION:** Framing

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506