INSPECTION REPORT

TYPE:

OWNER'S NAME: HART

Mono pour

PERMIT NUMBER: BP-15-00371

DATE:

8/4/2015

TIME STARTED:	10:28 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-15-22000-0011		
1. setbacks ok			
2. add ufer ground in footing before pouring			
3. monopour ok			
4. see interior and exterior footings at later date			
INSTRUCTIONS: add ground, ok to pour			
NEVT INCRECTION	1.		
NEXT INSPECTION: slab insulation/hydronics/footings/slab plumbing			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iessica.contratto @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			
TIT IT Had a direct, date 2, Enchang, 17/130320 - Ham office Ench 303 302 7300			