



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00396

OWNER'S NAME: EVANS

DATE: 3/4/2016

TYPE: Insulation

TIME STARTED: 10:23 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-16-08020-0018

1. Provide engineer letter for garage beam & waste line strap in great room
2. Insulation Ok
3. Interior Shear Ok
4. Ok to cover (except areas for engineer review)

INSTRUCTIONS: Provide engineer fix/Ok to cover (except areas with outstanding corrections)/Provide pictures of engineer fix

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506