



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00409 OWNER'S NAME: VOSHALL/OWENS
DATE: 7/31/2015 TYPE: Multiple (see notes)
TIME STARTED: 10:31 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 18-18-22054-0004

	1. Shearwalls:
	2. Shearwalls OK.
	3. Plumbing:
	4. DWV OK. 12#/15min. Verify Vent Penetration Through Roof at Insulation Inspection.
	5. Supply at Zero Pounds. Re Inspection Required.
	6. Mechanical:
	7. Bath Fan Exhaust Duct Not Connected.
	8. Range Vent Exhaust Not Installed.
	9. Minimal Heating Required for Occupancy. Verify Electric Wall Heaters at Final.
	10. Electrical Inspection Not Complete.
	11. Vented Windows or Passive Air Inlets Required.
	12. Dryer Exhaust Duct Not Installed.
	13. Framing:

INSTRUCTIONS: Make Corrections Above. OK to Insulate.

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00409 OWNER'S NAME: VOSHALL/OWENS
DATE: 7/31/2015 TYPE: Multiple (see notes)
TIME STARTED: 10:31 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 18-18-22054-0004

	Page 2
	14. Ledger Attachment at Exterior WALL Not Per Plan. Engineer To Approve Ledger Attachment and Use of "OSB" Type Rim Board as Ledger.
	15. Knee Bracing Required on Truss to Wall on Interior Per Plan. Knee Bracing Required On Post to GluLam on Exterior Per Plan.

INSTRUCTIONS: Make Corrections Above. OK to Insulate.

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506