



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00409 OWNER'S NAME: OWENS/VOSHALL  
DATE: 9/11/2015 TYPE: Final  
TIME STARTED: 11:04 AM INSPECTOR: Jeremy Haberman  
MAP NUMBER: 18-18-22054-0004

	1. WUIC Final Required Prior to Building Final
	2. SEWER and ACCESS OK
	3. WEathertite Exterior Required. Complete House Wrap and Siding.
	4. Complete Fire Separation at Exterior Door. Install Self Closing Hinge.
	5. Bedroom Windows Do Not Meet Egress. Minimum 30" x 30" Landing Required.
	6. Blower Door Not Complete.
	7. Energy Credits OK.

INSTRUCTIONS: Complete Above.

NEXT INSPECTION: Re Inspect.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506