



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00446      OWNER'S NAME: NEW SUNCADIA  
DATE: 11/9/2015      TYPE: Slab  
TIME STARTED: 1:50 PM      INSPECTOR: Jeremy Haberman  
MAP NUMBER: 20-15-18040-0003

	1. SLAB POURED PRIOR TO INSPECTION.
	2. Slab is Non-Bearing and Non Structural.
	3. Slab Rebar and Thickened Footings Verified Via Photograph Provided by Contractor.

INSTRUCTIONS: OK to Pour

NEXT INSPECTION: Shearwalls

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506