



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00619

OWNER'S NAME: YOUNG

DATE: 11/4/2015

TYPE: Framing

TIME STARTED: 11:43 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-20-02000-0018

	1. Replace Drywall Screws with Exterior Grade Screws or 16d Nails.
	2. Framing OK.
	3. NOTE: BP-15-00619 For Porch Roof Only. No Decks on this Permit.

INSTRUCTIONS: OK to Cover.

NEXT INSPECTION: Plumb/Mech.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremv.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506