



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00700

OWNER'S NAME: BOLSTAD

DATE: 3/11/2016

TYPE: Mechanical and plumbir

TIME STARTED: 12:00 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0076

1. Corrections Ok
2. Gas @ 15#/15 mins - Ok
3. Supply @ 54#/15 mins - Ok
4. DWV @ 4# - Needs to 5#/15 mins
5. Mechanical Ok

INSTRUCTIONS: Make corrections above/Verify DWV @ Framing

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506