INSPECTION REPORT

PERMIT NUMBER:	BP-15-00717	OWNER'S NAME:	CARLSEN
DATE:	3/8/2016	TYPE:	Rough-in plumbing
TIME STARTED:	12:01 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	17-19-02071-0004		
1. DWV @ 4# - Needs to be a minimum of 5#/15 mins 2. Corrections Ok 3. Ok to cover exterior 4. Plumbing RI Ok 5. Water @ 90#/15 mins - Ok 6. Permit card not on site			
RE-INSPECTION FEE	Re-Inspection DUE? NO YES		\$
	UIRED, RE-INSPECTION FEES MUST BE	PAID PRIOR TO SCHE	
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			

INSPECTION REQUEST LINE: 509-962-7694

ADDRESS:_

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506

iustin.bennett @co.kittitas.wa.us