INSPECTION REPORT

PERMIT NUMBER: BP-15-00717 OWNER'S NAME: CARLSEN

DATE:		8/24/2016	TYPE:	Final
TIME STARTED:		1:46 PM	INSPECTOR:	Lou Whitford
MAP NUMBER:		17-19-02071-0004		
1. C	1. CORRECTION; MIN R-30 REQUIRED IN CRAWL SPACE. DOCUMENTATION STATES R			
2. O	2. OK FIRE PLACE			
3. OK FINAL PLUMB/MECH				
INSTRUCTIONS: PROVIDE DOCUMENTATION FOR PROPER INSULATION IN CRAWL. MIN R-30				
NEXT INSPECTION: RE-FINAL				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
lou.whitford @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •				
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506				