



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00726

OWNER'S NAME: CASCADE VIEW INC

DATE: 1/29/2016

TYPE: Mechanical and plumbir

TIME STARTED: 9:43 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-18-27071-0154

1. Plumbing @ 80#/15 mins - Ok
2. DWV @ 7#/15 mins - Ok
3. Connect EF in downstairs bathroom
4. Plumbing RI Ok
5. Verified OA @ HVAC

INSTRUCTIONS: Make correction above/Verify @ Framing

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506